



SYSTEM 1 AREA
36,000 SQ. FT.

SYSTEM 2 AREA
45,528 SQ. FT.

PIPING NOTES

1. - DRAW ALL PIPE 1" TO 4" IN SIZE (SEE PLANS FOR ELEVATIONS) FROM CONCRETE STRUCT. WITH HANGER #1 AND #2.
 2. - HANG ALL 6" PIPE (SEE PLAN FOR ELEVATIONS) FROM CONCRETE STRUCT. WITH HANGER #2 AND #3.

SPRINKLER PIPING AND HEADS ARE LAYOUT PER NOTE SHOWN ON ELECTRICAL DWG. PE2.11 AND DETAIL 1/FP-1.

5/PA7.02(LIGHTS ARE SHOWN FOR REFERENCE ONLY) COORDINATION REQUIRED

PIPE SIZES IN THIS FLOOR SIMILAR TO SECOND FLOOR

REVISIONS		
NO.	DATE	DESCRIPTION
1	05/03/04	GENERAL CORRECTIONS REQUIRED BY RANCHO CUCAMONGA FIRE CONSULTANT

SYN	CHG	DATE	BY	CHK	DESCRIPTION	REVISION	RESULT
1	1	05/03/04	WY	WY	ISSUED FOR PERMIT	M	OK
2	1	05/03/04	WY	WY	ISSUED FOR PERMIT	M	OK
3	1	05/03/04	WY	WY	ISSUED FOR PERMIT	M	OK

TOTAL HEADS THIS PAGE 312

PROJECT: PARKING STRUCTURE
 ADDRESS: CITY
 TITLE: GROUND LEVEL PIPING PLAN
 DRAWN: WY DATE: ---
 WY
 FIRE SPRINKLER DESIGN SERVICES
 DRAWING NO. FP-1 OF SHEETS

DATE OF PLOT TIME 11:50
 FILE: FP-2.dwg